



(1) EC-TYPE-EXAMINATION CERTIFICATE (Translation)

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**

(3) EC-type-examination Certificate Number:

PTB 01 ATEX 1024



(4) Equipment: Control and distribution box, type 8146/5...-...

(5) Manufacturer: R. STAHL Schaltgeräte GmbH

(6) Address: Am Bahnhof 30, 74638 Waldenburg (Württ.), Germany

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 01-11059.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014:1997 + A1 + A2

EN 50017:1998

EN 50018:1994

EN 50019:2000

EN 50020:1994

EN 50028:1987

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of this Directive apply to the manufacture and supply of this equipment.

(12) The marking of the equipment shall include the following:

II 2 G EEx edmq ia/ib [ia/ib] T6, T5 or T4

Zertifizierungsstelle Explosionsschutz

Braunschweig, Juli 24, 2001

By order:

Dr.-Ing. H. Wehinger
Direktor und Professor



(13)

SCHEDULE

(14)

EC-TYPE-EXAMINATION CERTIFICATE PTB 01 ATEX 1024

(15) Description of equipment

The control and distribution box, type 8146/5....-... comprises a polyester resin enclosure of type of protection Increased Safety "e". It is designed to accommodate control and switch gear as well as measuring instruments and terminals for intrinsically safe and non-intrinsically safe circuits, and it may be provided with actuator elements, pilot lamps and inspection windows as required. The box area intended for intrinsically safe circuits will be marked by a specific colour (e.g. light blue). Connection will be by means of explosion-proof cable entries.

All installed and attached components have been tested and certified under a separate test certificate.

Technical data

Rated voltage*	up to	1100 V
Rated current*	max.	630 A
Rated cross section*	max.	240 mm ²

*) depending on type of terminal and explosion-proof components used

Ambient temperature range -40 °C to +55 °C

The ratings specified are maximum values, actual values will be subject to the electrical equipment used from case to case. Depending on the system conditions, the mode of operation, the utilisation category, etc., the manufacturer will define the definitive ratings which will be within the range of these limiting values and will comply with the relevant standards.

The composition of the protection symbol will be based on the types of protection of the components actually used.

(16) Test report PTB Ex 01-11059

(17) Special conditions for safe use

None;

Notes for installation and use

Equipment of the type of protection Intrinsic Safety "i" shall be installed in such a way that the clearances and creepage distances between intrinsically safe and non-intrinsically safe circuits as set forth in 60079-14 are duly accounted for.

If the clearance requirements for the connectors as specified in EN 50020 cannot be safeguarded with the system installation and layout, wiring that meets the quality criteria Increased Safety "e" shall be used, or the wiring shall be of the fail-safe type.

When using more than one intrinsically safe circuit, the rules and regulations for interconnection shall duly be observed.

The actual ambient temperature range will be based on the admissible temperature range of the components used.

This EC type-examination certificate as well as any future supplements thereto shall at the same time be regarded as supplements to Certificate of Conformity PTB No. Ex-95.D.3155.

(18) Essential health and safety requirements

The tests and the favourable results these have produced reveal that the control and distributor box of type 8146/5...-... meets the requirements of directive 94/9/EC as well as those of the standards quoted on the cover sheet.

Zertifizierungsstelle Explosionsschutz

Braunschweig, Juli 24, 2001

By order:

Dr.-Ing. H. Wehinger
Direktor und Professor




1. SUPPLEMENT

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 01 ATEX 1024

(Translation)

Equipment: Control and distribution box, type 8146/5...-...

Marking:  II 2 G EEx edmq ia/ib [ia/ib] T6, T5 or T4

Manufacturer: R. STAHL Schaltgeräte GmbH

Address: Am Bahnhof 30
74638 Waldenburg (Württ.), Germany

Description of supplements and modifications

The marking of the control and distribution box, type 8146/5...-... is supplemented by the specification of the gas group.

Therefore the marking is changed into:

 II 2 G EEx edmq ia/ib [ia/ib] IIA, IIB resp. IIC T6, T5 or T4

Zertifizierungsstelle Explosionsschutz

By order:


Dipl.-Phys. U. Völkel



Braunschweig, March 20, 2003

2nd SUPPLEMENT

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 01 ATEX 1024

(Translation)

Equipment: Control and distributor box, type 8146/5...-...

Marking: II 2 G EEx edmq ia/ib [ia/ib] IIA, IIB, IIC T6, T5 and T4

Manufacturer: R. STAHL Schaltgeräte GmbH

Address: Am Bahnhof 30, 74638 Waldenburg (Württ.), Germany

Description of supplements and modifications

The control and distributor box, type 8146/5...-..., may also be employed in areas in which a potentially explosive atmosphere as a mixture of dust and air can occasionally form.

It has been re-inspected on the basis of Standards EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-11, and EN 60079-18.

The marking will thus change to:

II 2 G Ex de ia/ib [ia/ib] mq IIA, IIB, IIC T6, T5, T4

II 2 D Ex tD A21 IP6X T 80 °C, T 95 °C, T 130 °C

Technical data

Rated voltage:* up to 1100 V
Rated current:* max. 630 A
Conductor cross section:* max. 240 mm²

*) depending on type of terminal and Ex components used

Ambient temperature range: -40 °C to +55 °C

Protection against el. shock, foreign objects

and water: min. IP65 in accordance with EN 60529

Rated values are maximum values, the actual electrical values are determined by mounted electrical apparatus. Within these limiting values complying with the appropriate standards the manufacturer specifies the final limiting values dependent on power supply specifications, operating mode, utilization category, etc.

The composition of the protection symbol is based on the types of protection of the components actually used.

Physikalisch-Technische Bundesanstalt



Braunschweig und Berlin

2nd SUPPLEMENT TO EC-TYPE-EXAMINATION CERTIFICATE PTB 01 ATEX 1024

Applied standards

EN 60079-0:2006	EN 60079-1:2004	EN 60079-7:2003	EN 60079-11:2007
EN 60079-18:2004	EN 61241-0:2006	EN 61241-1:2004	

Test report: PTB Ex 07-17134

Zertifizierungsstelle Explosionsschutz

Braunschweig, October 17, 2007

By order:


Dr.-Ing. M. Thedens
Oberregierungsrat

